



## A & J OIL TESTING

Date of Receipt: 12.11.08	Date of Report: 12.11.08	COC No: 0011826
Customer: UPTOWN OIL		
Job No:	PO No:	
Sample /Batch Number:-	071108N	
Sample Date:-		
Location:-	LONDON	

### CERTIFICATE OF CONFORMITY TO EN14214 STANDARD

Requirements for Biodiesel	Results	Test Methods	EN 14214 Limits	Units
Ester Content	96.9	EN 14103	min 96.5%	m/m
Methanol Content	0.013	EN 14110	max 0.2%	
Density @ 15° C	0.883	EN ISO 3675/EN ISO 12185	860 to 900	kg/m <sup>3</sup>
Viscosity @ 40 °C	3.87	EN ISO 3104	3.5 to 5.0	mm <sup>2</sup> /s
Water Content	349.2	EN ISO 12937	max 500	mg/kg
Flash Point	175	ISO 3679	Above 101	°C
% FFA	0.242	As oleic acid		
Acid Value	0.485			
Appearance	C&B			
Sediment	none			
Sludge	none			

HEAD OFFICE:- THE HEATH BUSINESS & TECHNICAL PARK, RUNCORN, CHESHIRE  
TEL: 01928 515175 Mobile: 07974575378 / 07894071987 FAX: 01928 515176.  
TECHNICAL CENTRE: UNIT 6A KAY BROW COMPLEX, KAY BROW, RAMSBOTTOM, NR BURY,  
LANCS. BL0 9AY. Tel:01706 822521/ 07894071986