



A & J OIL TESTING

Date of Receipt: 12.11.08	Date of Report: 12.11.08	Report No: AJ001826
Customer: UPTOWN OIL		
Job No:	PO No:	
Sample /Batch Number:-	071108N	
Sample Date:-	07.11.08	
Location:-	LONDON	

Requirements for Biodiesel	Results	Test Methods	EN 14214 Limits	Units
Ester Content	96.9	EN 14103	min 96.5%	m/m
Methanol Content	0.013	EN 14110	max 0.2%	
Density @ 15° C	883	EN ISO 3675/EN ISO 12185	860 to 900	kg/m ³
Viscosity @ 40 °C	3.87	EN ISO 3104	3.5 to 5.0	mm ² /s
Water Content	349.2	EN ISO 12937	max 500	mg/kg
Flash Point	175	ISO 3679	Above 101	°C
Acid Value	0.485	EN 14104	max 0.5	mg/KOH/g
% FFA	0.24			
Appearance	C&B			
Sediment	None			
Sludge	None			

HEAD OFFICE:- THE HEATH BUSINESS & TECHNICAL PARK, RUNCORN, CHESHIRE
TEL: 01928 515175 Mobile: 07974575378 / 07894071987 FAX: 01928 515176.
TECHNICAL CENTRE: UNIT 6A KAY BROW COMPLEX, KAY BROW, RAMSBOTTOM, NR BURY,
LANCS. BL0 9AY. Tel: 01707 82 2521 / 07894071986
www.aandjoiltesting.co.uk info@aandjoiltesting.co.uk